

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 06/A.E./Lab/PHED/Chowrai/2024

Dated: 22.02.2024

It is certified that an inspection team headed by Miss. Sita Markam, Assistant Eng.

(Name of Officers with designation) from Sub div. Chowrai PHED

inspected the I.T. International Public School, Thanta

(Name & Address of the school) on 21.02.2024, (date of inspection) and on the basis of

Water Test Report (Attached) bearing no U2063957518428227 dated 22.02.2024

of Subdivisional Lab Chowrai (PHED Lab) certified that the

I.T. International Public School, Thanta (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 21.02.2025

Signature with Seal

Name

Designation

Name & Address of the Office / Department



Miss. Sita Markam

Assistant Engineer

PHED  
Sub div. Chowrai

To  
I.T. International Public  
School, Thanta, Bichhua  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

  
सचिव

ऊँ साईं राम एजुकेशन एण्ड वेलफेयर  
सोसायटी वि.सू.आ.जि. छिन्दवाडा (म.प्र.)

  
PRINCIPAL

I.T. International Public School  
Jhanta Bichhua, Chhindwara (M.P.)  
Dist Code 23430701203, S.Code 30554

Sl. No.	Parameters tested	Unit of measurement	Test standard (IS:10500)	Relaxation of standard (Source) as per IS:10500	Test result value	Remarks
3	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
4	Fluoride (as F)	mg/l	1	15	0.450	
5	Iron (As Fe)	mg/l	1	No Relaxation	0.240	
6	Magnesium (As Mg)*	mg/l	30	100	18.240	
7	Nitrate (as NO <sub>3</sub> )	mg/l	45	No Relaxation	34.600	
8	pH*	NA	6.5-8.5	No Relaxation	7.340	
9	Sulphate (as SO <sub>4</sub> )	mg/l	200	400	59.400	
10	TDS*	mg/l	500	2000	256.000	
11	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	248.000	
12	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
13	Total Hardness (As CaCO <sub>3</sub> )*	mg/l	200	600	264.000	
14	Turbidity*	NTU	1	5	2.800	

**Note:**

- 1) \*Indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above.
- 3) The report shall not to be reproduced in full without approval of authority.
- 4) This is the end of the report.

Authorised signatory  
Seeta Markam (Test Lab Incharge)

\*\*\*\*\*This is an electronically generated report and does not require a signature\*\*\*\*\*

**Jal Jeevan Mission aims at potable tap water supply to every home**

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by IITM, Copyright © Copy Right 2024

सचिव

श्री साई राम एजुकेशन एण्ड रिसर्च प्राइवेट लि.  
सोसायटी विष्टा जि. छिन्दवाडा (म.प्र.)

PRINCIPAL

I.T. International Public School  
Jhamta Bichhua, Chhindwara (M.P.)  
Dist Code 23430701203, S. Code 50954

# Jal Jeevan Mission

Har Ghar Jal



## Sub Div. Lab Chaurai

PHED NEAR PANE TANKI CHAND ROAD SUB DIV. CHOURAI (Test Address only)

### Test report

Sample ID: U2063957518426227

### User Information

Name: pooja bobde Mobile: 9424325431

Email: govardhan.bobde@gmail.com Pin Code:

Full Address: Village- Zameta, Gram Panchayat- Zamta, Block- BICHHUA, District- Chhindwara, State- Madhya Pradesh

### Sample description

Source of Sample: I.T. INTERNATIONAL PUBLIC SCHOOL JHAMTA - DUGWEL Village: Zameta

Gram Panchayat: Zamta Block: BICHHUA

District: Chhindwara State: Madhya Pradesh

Address: Remark:

Latitude: Longitude:

Date & time of sample collection	Date & time of sample received in lab	Date & time of sample analysed	Date & time of report generation
16.02.2024   01:17:00 PM	16.02.2024   01:51:00 PM	21.02.2024   05:10:00 PM	22.02.2024   11:42:32 AM

### Test results

PRINCIPAL

I.T. International Public School

Jhamta Bichhua, Chhindwara (M.P.)

Dise Code 23430701203, S. Code 50954

Sr. No.	Parameter	Unit	Observed Value	Standard Value	Remarks
1	Calcium (as Ca)*	mg/l	75	200	73.300
2	Chloride (as Cl)*	mg/l	250	1000	33.980